

Tabela temperatur zasilania sieci ciepłowniczej

Temp. zewnętrzna	Temp. zadana	Temp. zewnętrzna	Temp. zadana
-18 C	118,00	-2 C	99,00
-17 C	116,00	-1 C	97,00
-16 C	115,00	0 C	95,00
-15 C	114,00	1 C	93,00
-14 C	114,00	2 C	91,00
-13 C	113,00	3 C	89,00
-12 C	113,00	4 C	87,00
-11 C	112,00	5 C	86,00
-10 C	112,00	6 C	84,00
-9 C	111,00	7 C	82,00
-8 C	110,00	8 C	80,00
-7 C	108,00	9 C	78,00
-6 C	107,00	10 C	77,00
-5 C	105,00	11 C	77,00
-4 C	103,00	12 C	77,00
-3 C	100,00	13 C	77,00

PREZES ZARZĄDU
PEC Sp. z o.o. w Piszcu

Marek Znojek